

**EL PASO WATER
PURCHASING DEPARTMENT
1154 Hawkins Blvd
El Paso, TX 79925**

Liquid Ferrous Chloride and Equipment Lease

BID NUMBER 102-17

ADDENDUM NUMBER 1

December 13, 2017

Attention of all respondents is directed to the following addendum to this bid:

Please add the attached Non-Divestment from Israel form to the bid specifications and turn in the completed notarized form with your bid submittal

Questions and Answers:

Question: Please confirm that you are feeding NSF ferrous chloride into 3 wastewater treatment plants and 1 water treatment plant?

Answer: EPW is feeding NSF ferrous chloride at the four locations listed on page 4 of the bid. The Boone Street Odor Control Station is not a wastewater treatment plant but a location on the collection system. Boone Street is within the service area of the Haskell Street Wastewater Treatment Plant.

Question: Please confirm that this is bid on a 13% iron basis of ferrous chloride?

Answer: The bid specifications on page 3 under Product Requirements requires a minimum percent ferrous iron (Fe₂) of 13% by weight.


Question: What is the current price and who is the current vendor?

Answer: Kemira Water Solutions Inc., \$0.98/LB

Question: How will the bids be evaluated since the product is bid separate from the equipment? You could conceivably have one vendor with the lowest product price and another vendor with the lowest equipment price.

Answer: This is a **Total Bid** type of procurement. The contract will be awarded to the lowest responsive, responsible bidder for the total bid of line items 1-5. The contract will not be awarded to multiple vendors.

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their submittal. Failure to acknowledge addendum(s), may result in rejection of bid.



Levi Chacon
Purchasing Agent

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT



R. Guevara
Sr. Purchasing Agent