

**EL PASO WATER  
PURCHASING DEPARTMENT  
1154 Hawkins Blvd  
El Paso, TX 79925**

**Liquid Ferrous Chloride and Equipment Lease**

**BID NUMBER 102-17**

**ADDENDUM NUMBER 2**

**December 14, 2017**

**Attention of all respondents is directed to the following addendum to this bid:**

**BID OPENING IS EXTENDED TO WEDNESDAY DECEMBER 20, 2017 AT 10:00AM**

**Questions and Answers:**

**Question:** There is no AWWA Standard for ferrous chloride. B407 is the standard for ferric chloride.

**Answer:** Page 2 of 23 of the bid proposal please delete and replace the Certifications section with the following:

In accordance with 30 T.A. C. Section 290.42 (e)(6)(I), Ferrous Chloride solution shall be supplied in accordance with ANSI/NSF Standard 60. Conformance with these standards must be obtained by certification of the product by an organization accredited by ANSI. This information must be included in bid submittal. FAILURE TO PROVIDE DOCUMENTATION OF ANSI/NSF CERTIFICATION MAY RESULT IN DISQUALIFICATION OF THE BID SUBMITTAL. Provide a current Safety Data Sheet (SDS) for the Product.

**Delete and replace:**

**DELETE EXCEL WORKSHEET AND REPLACE WITH EXCEL WORKSHEET ADDENDUM 2**

On page 3 of 23 of the bid proposal please delete section B. MANUFACTURING PROCESS and replace with the following:


**B. MANUFACTURING PROCESS:** The iron source for the manufacture of the Liquid Ferrous Chloride shall be soft iron, iron oxide, or another source approved by El Paso Water Utilities. The Liquid Ferrous Chloride can be produced from iron scraps or pickling liquors.

On page 4 of 23 of the bid proposal please delete section H. TRACE ELEMENTS and replace with the following:

H. TRACE ELEMENTS: The Ferrous Chloride solution shall contain trace elements at concentrations less than or equal to 0.02 %, and the following maximum contaminant concentrations (mg/kg):

Metal .....	Maximum concentration (mg/kg)
Arsenic.....	1.00
Cadmium .....	0.50
Chromium (total).....	125
Chromium (hexavalent).....	0.10
Copper.....	125
Lead.....	10.0
Nickel.....	50.0

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their submittal. Failure to acknowledge addendum(s), may result in rejection of bid.



Levi Chacon  
Purchasing Agent

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT