

**EL PASO WATER UTILITIES  
PURCHASING DEPARTMENT  
P.O. BOX 511  
EL PASO, TEXAS 79961**

**COLD WATER POSITIVE DISPLACEMENT METER AND COMPOUND  
METERS WITH STRAINERS**

**BID NUMBER 24-17**

**ADDENDUM NUMBER 1**

**AUGUST 14, 2017**

Attention of all bidders is directed to the following addendum to this Bid Proposal:

**1.) BID CURRENTLY READS: PAGE 7**

**SPECIFICATIONS FOR COLD WATER POSITIVE DISPLACEMENT METER AND COMPOUND  
METERS WITH STRAINERS**

Lay Lengths

2.05 Lay lengths for dual register single body compound water meter and strainer:

Size	Meter	Strainer	Meter and Strainer
3 inch	18 inches	7 inches	25 inches
4 inch	21 inches	9 inches	30 inches
6 inch	25 inches	9 inches	34 inches

**2.) BID CHANGE TO READ: PAGE 7**

**SPECIFICATIONS FOR COLD WATER POSITIVE DISPLACEMENT METER AND COMPOUND  
METERS WITH STRAINERS**

Lay Lengths


2.05 Lay lengths for dual register single body compound water meter and strainer:

Size	Meter	Strainer	Meter and Strainer
3 inch	17 inches	6 inches	23 inches
4 inch	20 inches	7-1/2 inches	27 inches
6 inch	24 inches	9 inches	33 inches

**PAGE 2 ADDENDUM NUMBER 1 – COLD WATER POSITIVE DISPLACEMENT METER AND COMPOUND METERS WITH STRAINERS.**


- 3.) REPLACE PAGE 3 OF CURRENTLY POSTED SPECIFICATIONS AND REPLACE WITH UPDATED PAGE 3 OF SPECIFICATION. SEE ATTACHED.**

**Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their Bid submittal. Failure to acknowledge addendum(s), may result in rejection of bid.**

  
8/14/17  
Levi J. Chacon  
Purchasing Agent

---

**BIDDER'S ACKNOWLEDGEMENT OF RECEIPT**

 8-14-17  
CGP

## SPECIFICATIONS FOR COLD WATER POSITIVE DISPLACEMENT METER AND COMPOUND METERS WITH STRAINERS

### 1.0 SCOPE

- A. **General:** This specification covers requirements for meters and appurtenances that will be used in customer water services. The meter types, sizes, and estimated quantities are as listed in the Price Proposal Form to be completed by the Proposers.
- B. **Quantities:** The quantities reflected in the Price Proposal Form are merely estimates based on the best available information. Payment to the successful Proposer(s) or Vendor(s) will be based on actual quantities ordered, shipped, received and accepted. El Paso Water does not guarantee the purchase of any specific type or amount of goods and services during the period of the agreement. The amount of goods and services ordered may vary or combinations changed, depending upon actual needs of the Utility.
- C. **Applications:** The meters specified herein and purchased under the resulting contract, will be used for the measurement of potable cold water in residential, commercial and industrial services.

### GENERAL REQUIREMENTS

The requirements specified in this section are common to all meters included in the scope of the Bid. Specifications applicable to specific meters are contained in the Technical Specifications.

### QUALIFICATIONS & REFERENCES

- A. Qualified Proposers may include manufacturers, manufacturer representatives, distributors, or other firms capable of providing the goods and services specified herein.
- B. The manufacturers of proposed meters shall be engaged regularly and continuously for at least ten (10) Year's in the production of meters for the water utility industry.
- C. Meters proposed shall have a minimum of three (3) years of satisfactory operating experience as Marketable products. Proposers shall list any meter offered that has not been in production for three (3) years. Certified copies of sales records may be required as proof that the manufacturer has been selling meters as stipulated.
- D. Meters not meeting the 3-years satisfactory experience can be supplemented with a minimum of three (3) years R&D and satisfactory evaluation by El Paso Water.
- E. Meters proposed shall have been in satisfactory use for a minimum of one (1) year in a municipal water system.
- F. Proposers shall provide three (3) references with at least 1 reference of similar size to El Paso Water