

**EL PASO WATER
PURCHASING DEPARTMENT
1154 HAWKINS BLVD.
EL PASO, TEXAS 79925**

**Removal, Purchase and Installation of a Crane
BID NUMBER 42-18**

ADDENDUM NUMBER 1

March 16, 2018

Attention of all bidders is directed to the following addendum to this Bid Proposal:

A. Response(s) to Bidder's question(s):

Question: Is there an estimated project timeline?

Answer:

A. **Four weeks for removal, installation and testing**

B. **Lead time based on manufacturer (EPWater estimates approximately 12 weeks)**

Question: Will El Paso Water accept Galvanized Coatings?

Answer: Galvanized coating will not be allowed. Any exceptions to the specified coating shall be capable of withstanding a corrosive environment as stated on Bid 42-18 specifications.

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their bid submittal. Failure to acknowledge addendum(s), may result in rejection of bid.


Levi Chacon
Purchasing Agent

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT


RGuevara