

**EL PASO WATER UTILITIES
PURCHASING DEPARTMENT
P.O. BOX 511
EL PASO, TEXAS 79961**

UTILITY METAL FITTINGS AND SERVICE PARTS

BID NUMBER 87-17

ADDENDUM NUMBER 1

NOVEMBER 8, 2017

Attention of all bidders is directed to the following addendum to this Bid Proposal:

- 1. CURRENT BID OPENING DATE IS: NOVEMBER 13, 2017 AT 11:00 A.M.**

BID OPENING DATE CHANGED TO: NOVEMBER 17, 2017 AT 10:00 A.M.

- 2. PAGE 3 OF CURRENT BID READS: Service Saddles:** Shall be two or three piece all-bronze, double strap with National Coarse Class 2 thread. Saddles shall be suitable for Class 200 asbestos cement pipe, cast iron pipe and ductile iron pipe with double straps. Saddles for C-900 or C-905 polyvinyl chloride (PVC) pipe shall be single strap. Saddle body shall extend 180 degrees around pipe. Acceptable manufacturers and models are as follows: Ford Meter Box Co. Model S90, James Jones Co. J-996, A.Y. McDonald Mfg. Co. 3805, Mueller H-1344X.
- 3. CHANGE TO READ: Service Saddles:** Shall be two or three piece all-bronze with National Coarse Class 2 thread. Saddles for Class 200 asbestos cement pipe, cast iron pipe and ductile iron pipe shall be double straps. Saddles for C-900 or C-905 polyvinyl chloride (PVC) pipe shall be single strap and shall be hinged for 8-inch diameter and smaller. Saddle body shall extend 180 degrees around pipe. Acceptable manufacturers and models are as follows: Ford Meter Box Co. Model S90, James Jones Co. J-996, A.Y. McDonald Mfg. Co. 3805, Mueller H-1344X.
- 4. PAGE 4 OF CURRENT BID READS: DELIVERY REQUIREMENTS:**

Suppliers will be provided with a Material Release order by FAX OR E-MAIL for delivery of the UTILITY METAL FITTINGS AND SERVICE PARTS. Acknowledgement of order must be received by Fax or E-mail within 24 hours of when that order was placed. Tracking and shipping details must be received within five days of receipt of order. Upon written notification, delivery is to be made in complete shipments, which will continue throughout the Contract Period. Deliveries will be accepted Monday through Friday ONLY DURING THE HOURS OF 9:00 A.M. TO 2:30 P.M. at the El Paso Water Utility Warehouse, 9751 Pan American Bldg. B, El Paso, Texas 79927. Delivery of each order shall be made within ten (10) days of written notification.

SERVICE DELIVERY FOR EXPEDITED AND REQUIRED ITEM- (A) IF SUPPLIER DOES NOT HAVE BIDED AND AWARDED CATEGORY ITEM(S) IN STOCK, THE AWARDED SUPPLIER FOR THAT CATEGORY WILL BE OFFERED NO MORE THAN (24) HOURS TO HAVE THE ITEM(S) IN THAT PARTICULAR CATEGORY IN THEIR FACILITY WITH IMMEDIATE NOTIFICATION FROM THE SUPPLIER TO EL PASO WATER OF THAT ITEMS AVAILABILITY.


4. CHANGE TO READ: DELIVERY REQUIREMENTS:

Suppliers will be provided with a Material Release order by FAX OR E-MAIL for delivery of the UTILITY METAL FITTINGS AND SERVICE PARTS. Acknowledgement of order must be received by Fax or E-mail within 24 hours of when that order was placed. Tracking and shipping details must be received within five days of receipt of order. Upon written notification, delivery is to be made in complete shipments, which will continue throughout the Contract Period. Deliveries will be accepted Monday through Friday ONLY DURING THE HOURS OF 9:00 A.M. TO 2:30 P.M. at the El Paso Water Utility Warehouse, 9751 Pan American Bldg. B, El Paso, Texas 79927. Delivery of each order shall be made within ten (10) days of written notification.

The expedited delivery section or reference to overnight delivery instruction for stock fulfillment in (24) hours has been removed in its entirety.


5. REPLACE CURRENT POSTED EXCEL WITH UPDATED EXCEL- SEE ATTACHED.

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their Bid submittal. Failure to acknowledge addendum(s), may result in rejection of bid.



Levi J. Chacon
Purchasing Agent

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT



CGP