



**GENERAL NOTES:**

1. POST TYPE HYDRANT IS A SPECIAL USE HYDRANT AND SHALL NOT BE USED FOR FIRE FIGHTING.
2. ALL RECLAIMED HYDRANTS SHALL BE PAINTED PURPLE.
3. COMPLY WITH REQUIREMENTS OF AWWA C-502, DRY BARREL FIRE HYDRANTS AND AWWA C-550, PROTECTIVE EPOXY INTERIOR COATINGS FOR VALVES AND HYDRANTS.

**CONSTRUCTION KEY NOTES:**

- A. OPERATING NUT – NATIONAL STANDARD PENTAGON MEASURING 1 1/2" FROM POINT TO FLAT.
- B. ONE 2 1/2" HOSE NOZZLE.
- C. 2 1/4" MAIN VALVE.
- D. 2" HYDRANT ELBOW.

STANDARD  
DETAIL

DATE: 9/6/2006  
REV:

RECLAIMED WATER HYDRANT  
(POST TYPE HYDRANT)

N.T.S.



DETAIL No.  
412