



SECTION

**GENERAL NOTES:**

1. MANHOLE CONNECTOR SHALL BE KOR-N-SEAL OR EQUAL MEETING THE REQUIREMENTS OF ASTM C-923. CONNECTOR SHALL BE FURNISHED BY CONTRACTOR.

**CONSTRUCTION KEY NOTES:**

- A. PRECAST MANHOLE BARREL.
- B. FLEXIBLE CONNECTOR.
- C. PIPE CLAMP SS 316.
- D. APPROVED PIPE.
- E. PRECAST MANHOLE BASE.
- F. GROUT AS REQUIRED TO FORM SMOOTH CHANNEL TO MANHOLE INVERT.
- G. PIPE OPENINGS/KNOCKOUTS AS REQUIRED TO FIT PIPE SIZE.
- H. EXPANSION BAND SS 316.
- I. FILL SPACE WITH GROUT.

STANDARD  
DETAIL

DATE: 11/1992  
REV: 8/13/2009

PIPE CONNECTION TO MANHOLE

N.T.S.



DETAIL No.  
376