



GENERAL NOTES:

1. IN GROUNDWATER CONDITIONS ONLY, P.V.C. SADDLES OR TEES ARE TO BE ENCASED WITH CLASS B CONCRETE.
2. UNDER CERTAIN CONDITIONS FIELD INVESTIGATIONS WILL BE REQUIRED TO DETERMINE THE ADEQUACY OF THE DEPTH ON THE LATERAL.

CONSTRUCTION KEY NOTES:

- A. SERVICE LINE TO BE EXTENDED ABOVE GROUND WATER LEVEL OR TO A DEPTH OF THE INTERSECTING SERVICE LINE, OR TO WITHIN 6' OF SURFACE (WHICH EVER IS APPROPRIATE & SAFER).
- B. PLASTIC METALLIC MARKING TAPE RISING TO WITHIN 6" OF GROUND SURFACE OR METALLIC DISK.
- C. WOODEN STAKE (1"x2"x36") VERTICALLY PLACED AT PLUGGED END OF RISER.

STANDARD
DETAIL

DATE: 11/1992
REV: 1/23/2009

SEWER SERVICE RISER CONNECTION

N.T.S.



DETAIL No.
390