



SECTION

GENERAL NOTES:

1. SEPARATION DISTANCES SHALL FOLLOW TEXAS COMMISSION ON ENVIRONMENTAL QUALITY STANDARD REQUIREMENTS.
2. MINIMUM SEPARATION DISTANCES SHOWN. IF CONDITIONS DO NOT ALLOW FOR INDICATED DISTANCES REFER TO DETAILS 161, 162 & 163.
3. RECLAIMED WATER LINE AT OR ABOVE SEWER LINE.

STANDARD
DETAIL

DATE: 8/3/2006
REV: 3/28/2007

SEPARATION DISTANCE
POTABLE WATER, SANITARY SEWER AND
RECLAIMED WATER

N.T.S.



DETAIL No.
160