



T = WALL THICKNESS

SECTION A-A

CONSTRUCTION KEY NOTES:

- A. SCHEDULE 40 THREADED STEEL COUPLING
- B. 2 - No. 4 REBAR CONTINUOUS, EACH WAY.
- C. MINIMUM 3500psi CONCRETE 2'x2' SQUARE COLLAR.
- D. 12" SUBGRADE @ 95% PER ASTM D-1557.

STANDARD
DETAIL

DATE: 8/21/2006
REV:

BREAK-A-WAY COUPLING

N.T.S.



DETAIL No.
263-5