



FIRE METER INSTALLATION

GENERAL NOTES:

1. USE OF HYDRANT REQUIRES VALID HYDRANT USE PERMIT. CONTACT EPWU ENGINEERING DEVELOPER SERVICES SECTION FOR APPLICATION.
2. METER AND BACKFLOW DEVICE SHALL BE FULLY SUPPORTED WHEN CONNECTED TO FIRE HYDRANT.
3. METER AND BACKFLOW DEVICE SHALL BE APPROVED BY EPWU. (MS-30) METER MUST BE INSPECTED AND NUMBERED BY EPWU BEFORE BEING PLACED IN SERVICE.
4. METER SHALL BE TESTED ANNUALLY BY EPWU.
5. BACKFLOW DEVICE SHALL BE TESTED ANNUALLY AND COPY OF TEST SHALL BE SENT TO EPWU, BEFORE USAGE WILL BE ALLOWED.
6. CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE TO FIRE HYDRANT DURING USE.

CONSTRUCTION KEY NOTES:

- A. EXISTING FIRE HYDRANT
- B. FIRE HYDRANT METER
- C. BACKFLOW PREVENTER
- D. 3" GATE VALVE WITH HANDWHEEL
- E. SANDBAGS OR EQUAL FOR SUPPORT

STANDARD
DETAIL

DATE: 12/14/2005
REV:

FIRE HYDRANT CONSTRUCTION METER

N.T.S.



DETAIL No.
290-10